13. That measures are taken to protect buildings, installations and equipment from fire that are commensurate with the risks and are appropriate to the value of teaching, research or commercial importance of those assets.

Building Construction and Alarm Systems

University buildings are constructed of noncombustible materials, primarily brick and concrete. Walls, hallways, ceilings and floors are made of concrete, concrete block or other noncombustible materials. Each hall is equipped with a fire alarm system that includes manual pull stations, horns, strobe lights and smoke detectors. The alarm systems and fire extinguishers are routinely tested. Students are advised that initiating a false alarm is a violation of the Student Code of Conduct.

Prevention and Inspection Programs

Coordinating university-wide safety programs is a responsibility of the Safety and Emergency Preparedness Committee, Public Safety, Facilities Administration and Planning, and the Environmental Health and Safety Department. They coordinate the fire safety programs on campus and train Residence Life staff on fire safety policies and procedures, providing educational materials to students on a variety of safety issues. University policies prohibit fire hazards in residence hall rooms such as candles, many electrical appliances, cooking devices, and room heaters. At the start of each semester, students are oriented on fire alarms and evacuation procedures and each hall conducts a fire drill during the first two weeks of each semester. Fire safety inspections are made with the Florence Fire Department on a regular basis to insure egress routes are maintained and that fire safety issues are addressed in a timely manner.

Residence Hall Fire Safety

Fire alarm systems are installed in all residence halls. The system includes automatic smoke detectors, alarm signals, and enunciators. The alarh99 Tm0 g0 G[ )]Tf0TQq0912 0 6n3 that

5.

know what type of extinguisher to use. Even if you have an ABC extinguisher, there may be something in the fire, which is going to explode or produce highly toxic smoke. If you don’t know what is burning, let the fire department handle it.

2. The fire is spreading rapidly beyond the spot where it started. The time to use an extinguisher is in the incipient, or beginning, stages of a fire. If the fire is spreading quickly, evacuate the building, closing doors and windows behind you as you leave.

3. You don't have adequate or appropriate equipment. If you don't have the correct type or large enough extinguisher, do not to try to fight the fire.

4. You might inhale toxic smoke. If the fire is producing large amounts of smoke that you would have to breathe in order to figh

Table 2 – Fire Extinguisher Details

Extinguisher Type	Details
Water - Air-pressurized Water Extinguishers (APW)	Water is one of the most commonly used extinguishing agents for type A fires. You can recognize an APW by its large silver container. They are filled about two-thirds of the way with ordinary water, then pressurized with air. In some cases, detergents are added to the water to produce a foam. They stand about two to three feet tall and weigh approximately 25 pounds when full. **Never use water to extinguish an electrical fire. Water can conduct electricity.** APWs extinguish fire by cooling the surface of the fuel to remove the "heat" element of the fire triangle.
CO_2 or Dry Chemical - Carbon Dioxide Extinguishers	This type of extinguisher is filled with Carbon Dioxide (CO_2), a non-flammable gas under extreme pressure. These extinguishers put out fires by displacing oxygen, or taking away the oxygen element of the fire triangle. Because of its high pressure, when you use this extinguisher pieces of dry ice shoot from the horn, which also has a cooling effect on the fire. NOTE: Do not touch the plastic discharge horn on CO2 extinguishers, it gets very cold0W*nBT/F1 12 Tf1 0 0 1 176.40 lt2r nBT w0 G[ )]TH

Using a Fire Extinguisher

The following steps should be followed when responding to incipient stage fire:

1. Sound the fire alarm and call the fire department, if appropriate.
2. Identify a safe evacuation path before approaching the fire. Do not allow the fire, heat, or smoke to come between you and your evacuation path.
3. Select the appropriate type of fire extinguisher.
4. Discharge the extinguisher within its effective range using the P.A.S.S. technique (pull, aim, squeeze, sweep).
5. Back away from an extinguished fire in case it flames up again.
6. Evacuate immediately if the extinguisher is empty and the fire is not out.
7. Evacuate immediately if the fire progresses beyond the incipient stage. An "incipient stage fire" is one in the initial or beginning stage and which can be controlled or extinguished by portable fire extinguishers, class II standpipe, or small hose systems without the need for protective clothing or breathing apparatus.

Most fire extinguishers operate using the following P.A.S.S. technique:

1. ... Pull the pin. This will also break the tamper seal.
2. ... Aim low, pointing the extinguisher nozzle (or its horn or hose) at the base of the fire.
3. ... Squeeze the handle to release the extinguishing agent.
4. ... Sweep from side to side at the base of the fire until it appears to be out. Watch the area. If the fire re-ignites, repeat steps 2 - 4.



If you have the slightest doubt about your ability to fight a fire....EVACUATE IMMEDIATELY!